

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Mr. Manish Thackar** In charge Chemist Maintenance Sub Division No. 8 PHED Indore inspected **St. Norbert School RR Cat Road Rangwasa, Indore 03.08.2026** and on the basis of Test report bearing No. DW/0803021 dated 06.08.2026 from Water Testing Laboratory, IMC Musakhedi Indore certified that the **St. Norbert School RR Cat Road Rangwasa, Indore** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Government norms.

This certificate is valid till 01 Year from date of issue with condition of periodic Maintenance of water purification system.

Date of Issue

06.08.26

R.S. 91



MANAGER
ST NORBERT SCHOOL
RRCAT - RAU ROAD
RANGWASA
INDORE

P. Sharma
Mr. Paveen Sharma
Assistant Engineer
Maint. Sub Dn. No. 8
PHE, INDORE (M.P.)



Water Testing Laboratory
Narmada Project Campus, Musakhedi
Indore M.P. India 452001

Phone 0731-2712846 Email: ee2_narmada@rediffmail.com,
waterlabimc@outlook.com

Test Report

Customer Name and Address		St. Norbert School RR Cat road , Rangwasa Indore		Date of Receipt		03.08.2026
				Date of commencement		03.08.2026
Contact No.				Date of Completion		06.08.2026
Received Sample Discription		1 ltr PB & 250 ml SGB R.O. Unit			Lab reference DW/0803021	
				IS-10500-2012		Result
S.No.	Test	Method	Unit	Desirable Limit	Permissible Limit	
1	pH At 25.4°C	IS 3025 (Part- 11): 2022	pH Scale	6.5-8.5	No Relaxation	6.94
2	Colour	IS 3025 (Part 4): 2021	CU	5	15	0
3	Odour	IS 3025 (Part- 05): 1983	-	Agreeable	Agreeable	Agreeable
4	Taste	IS 3025 (Part - 07): 1984	-	Agreeable	Agreeable	Agreeable
5	Turbidity	IS 3025 (Part 10): 1984	NTU	1	5	0.21
6	Total Dissolved Solids	IS 3025 (Part 16): 1984	mg/l	500	2000	70
7	Total Hardness	IS 3025 (Part 21) : 2009	mg/l	200	600	22
8	Total Alkalinity	IS 3025 (Part 23): 1986	mg/l	200	600	11
9	Nitrate	IS 3025 (Part 34) : 1988	mg/l	45	No Relaxation	1.11
10	Ammonia	IS 3025 (Part - 34): 1988	mg/l	0.5	No Relaxation	BDL(0.05)
11	Fluoride	IS 3025(Part 60): 2008	mg/l	1	1.5	0.07
12	Iron	IS 3025 (Part - 53): 2003	mg/l	0.3	1	BDL
13	Chloride	IS 3025(Part-32) :1988	mg/l	250	1000	7
14	Sulphate	IS 3025(Part) :	mg/l	200	400	1.54
15	Fecal Coliform	IS 1622 : 1981	CFU/100ml	Shloud not be detected in 100 ml		ND

Opinion:-

Note:-

1. The legal liabilities limited up to the analytical charges only.
2. The results are related only to the sample tested.
3. The reports shall not be reproduced except in full without approval.
4. Sample not drawn by the Laboratory.
5. The result apply to the sample as received.

Abbreviation 'ND' Not detected , 'BDL' Below Determination limit

*** End of Report ***



MANAGER
ST NORBERT SCHOOL
RRCAT - RAU ROAD
RANGWASA
INDORE

